



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041



Water Sample Analysis report of samples collected from "Sunshine Convent Public School" Plot No 10/21, Main Hastal – Ranhaula road, Nr. Pradhan Chowk, Vikas Nagar, New Delhi – 110059 vide Challan No. 31 Dt- 27.04.2026.

S1:- Bore Water at above site.

S2:- Drinking Point with (R.O.) at above site.

S. No.	Particulars THE TEST REPORT IS FOR THIS PARTICULAR WATER SAMPLE ONLY.	Units	Limit		S1	S2
			Acceptable	Permissible		
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	29.05.2026	
2.	Date of Analysis	-----	--	--	01.06.2026	
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	4.0	1.2
6.	PH value	-----	6.5	8.5	7.2	6.6
7.	Electrical Conductivity	µmho/cm	--	--	1615	276.6
8.	Total dissolved solids	mg/l	500	2000	1050	179.7
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	90	52
11.	Total Hardness	mg/l	200	600	322	16
12.	Calcium Hardness	mg/l	--	--	156	08
13.	Magnesium Hardness	mg/l	--	--	166	12
14.	Calcium as Ca	mg/l	75	200	62.4	3.2
15.	Magnesium as Mg	mg/l	30	100	39.8	2.8
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	28.2	2.8
19.	Sulphate	mg/l	200	400	80	28
20.	Chloride	mg/l	250	1000	178	36
21.	Fluoride	mg/l	1	1.50	0.32	0.14
22.	Dissolve Iron	mg/l	1	N.R.	0.16	0.08
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	NIL	Nil
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		42	0

REMARKS:- As per the tested parameters Sample-S1 is found Unsatisfactory & cannot be used for drinking purpose whereas Sample – S2 is found Satisfactory and can be used for drinking purpose.

ACWA

Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41

CHEMIST

Principal
Sunshine Convent Public School
Vikas Nagar, New Delhi-59

Manager
Sunshine Convent Public School
Vikas Nagar, New Delhi-59

A/BACT.



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



NO. DHO/WZ/2026/D-374

Dated: 05/05/26

HEALTH CERTIFICATE

1. Name of the School Sunshine Convent Public School
2. School Address Plot No-10/21, Main Hastal-Ranhaul Road, Near Pradhan Chowk, Vikas Nagar, N.D-110059
3. No. of shifts 01 Timing 08 AM to 01 PM
4. No. of Students: Boys 360 Girls 281 Total 641
5. No. of Staff: Gents 04 Ladies 28 Total 32

Accommodations provide for classroom as under:-

Floor area in the classroom is sufficient/ not sufficient Sufficient

Classes are well lighted/ill lighted Well lighted

Classrooms are well ventilated/ill ventilated Well ventilated

Classes are kept/ not kept neat and clean neat & clean

Building/ classrooms require/ don not require white wash etc. not required

Drinking water is wholesome/ not wholesome wholesome

Latrine arrangement is sanitary/ insanitary sanitary from health point of view

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability unauthorized construction and fire safety. This certificate is valid for one year from date of issue.

[Signature]
Principal
Sunshine Convent Public School
Vikas Nagar, New Delhi-59

[Signature]
Manager
Sunshine Convent Public School
Vikas Nagar, New Delhi-59

[Signature]
Dy. Health Officer
West Zone
Dy. Health Officer
West Zone